

NO.NC/QC/YD/2020-21/W4 AB

Date: 15-07-2020

To,
The Executive Engineer,
Yelahanka Division
Bangalore.

"FREQUENCY AND QUALITY REPORT"

Dear Sir,

Subject: Regarding Quality Report for the below mentioned work.

Name of work: Improvements to roads and drains at Yelahanka A and B Sector and MIG 3rd phase in ward no -04 of yelahanka satellite town sub division (Packagr-09)

Item No	Description of work	Unit	Qty	No of Samples Tested	Standards
1	KSRRB M2100-10. Providing and laying Plain cement concrete of mix 1:3:6 with OPC @	Cum	989.88	9	Per 100 cum
2	Providing and laying plain/reinforced cement concrete for side drains using M20	Cum	535.86	22	Per 50 cum
3	KSRRB - M2300-14: Providing TMT steel reinforcement for R.C.C work including	Ton	35.11	3	Per each dia
4	Providing and fixing pre cast solid cement concrete kerb stones made out of CC 1:2:4	Nos	1714.00	4	Per 500 Nos
5	Construction of granular sub-base Grading-V as Sub-base and drainage layer by providing	Cum	395.49	1	Per 400 cum
6	Constructing un-reinforced, plain cement concrete for pavements using Grade	Cum	715.96	30	Per 50 cum

With respect to the above subject & name of the work, we have inspected the work and the Quantity and Quality of above mentioned items of the work was found to be completed satisfactorily for the 1st and Final bill

Thanking you,

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಯಲಹಂಕಾ ಉಪನಗರ ಉಪವಿಭಾಗ.
ಬಿ.ಬಿ.ಎಂ.ಡಿ. ಬೆಂಗಳೂರು-106

With Regards,
For Newzen Consultants Bangalore



R